



Schenectady County  
Purchasing Department  
**ADDENDUM**

620 State St.-6<sup>th</sup> Floor  
Schenectady, NY 12305  
[Purchasing@schenectadycounty.com](mailto:Purchasing@schenectadycounty.com)  
518.388.4242

**RFB-2021-18**  
Sheriff Substation Interior Fit-UP  
**ADDENDUM #2**

**April 5, 2021**

**Project Location: 130 PRINCETOWN PLAZA, SCHENECTADY, NY 12306**

**C2 DESIGN PROJECT #2014**

---

This **Addendum #2** forms part of the Contract Documents and modifies the original bidding documents as dated March 5, 2021.

**General Information**

1. This addendum changes the documents for Bid #RFB-2021-18.

**Revisions to Contract Drawings**

**General RFI's (Addendum #1 Revised Response and Clarifications)**

1. On the plumbing sanitary underground and aboveground piping spec it states early in the spec Service Weight Cast Iron for Underground with Cast Iron No-Hub for Aboveground, then later in the spec under Piping Materials it states the use of Sch 40 PVC Pipe and Fittings on both applications. Please advise.
  - a. **Void** - response: While both materials are code compliant, the design team recommends using the cast iron piping for the drainage systems.

**Revised** – response: (Provide for sch 40 galvanized steel piping from the pump station discharge to the connection into the existing overhead cast iron drain line.)

(Provide underfloor sanitary drainage & vent piping in sch 40 PVC piping using DWV pattern fittings. All piping concealed within walls or above ceilings can be installed also with sch 40 PVC piping and DWV pattern fittings.)

(Provide for Cast Iron drain and vent piping using no hub connectors for all drainage and vent piping located above the floor that is exposed to the space.) This will prevent PVC piping (which can be brittle) from being damaged.



Schenectady County  
Purchasing Department  
**ADDENDUM**

620 State St.-6<sup>th</sup> Floor  
Schenectady, NY 12305  
[Purchasing@schenectadycounty.com](mailto:Purchasing@schenectadycounty.com)  
518.388.4242

2. Under the same spec section, it states that Pex Piping System can be used on water distribution system, but only where noted? I haven't found anywhere that it's noted to be used? It states that a Pro press Piping System can be used with no exceptions. Please advise.
  - a. **Void** - response: Provide piping systems as noted in documents.

**Revised** – response (The Pex Piping systems are not to be used. Provide for copper piping using the mechanical fastener systems.)

*Apart from the items outlined in this addendum, all other provisions of the original scope shall remain in effect.*

**END OF ADDENDUM #2**