



Schenectady County
Purchasing Department

620 State St.-2nd Floor
Schenectady, NY 12305
Purchasing@schenectadycounty.com
518.388.4240

ADDENDUM

RFB-2022-48
SCHENECTADY COUNTY JAIL
CORRECTIONAL FACILITIES UPGRADES

ADDENDUM #1

Issued Date: 09/08/2022

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

CONTENTS/RESPONSE TO QUESTIONS/REFERENCE TO ATTACHMENTS

Attachments:

- **#RFB-2022-48 Pre-bid Walk through (09/01/2022): Attended Contractor list**
- **Specifications Section 01 21 00 – Allowances**
- **Specification Section 000110 – Table of Content: 012100 Allowances (Addendum#1)**
- **Specification Section 000401 – Bid Form: Base Bid + Allowance (Addendum#1)**

General RFI's:

1. Do existing floors at locations for New Epoxy application require grinding or smoothing of raised concrete areas?
 - a. Response: Following removal of existing floor painted surface Field Verify entire floor surface for existing raised concrete edges, or disformed raised surfaces which stands higher than 1/16". Fill and/or Grind all found surface smooth prior to application of Epoxy System. See specifications for surface preparation.

Please acknowledge this addendum on your bid form.

END OF ADDENDUM #1